

Office of Sub Divisional Engineer, W/S & Sanitation Sub Division No. 2, Sri
Muktsar Sahib

ਨੰਬਰ ੨੧੮

ਮਿਤੀ 25-4-2023

ਸਰਟੀਫਿਕੇਟ

ਤਸਦੀਕ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ ਆਪ ਵੱਲੋਂ ਪਾਣੀ ਦਾ ਸੈਂਪਲ ਪੱਤਰ ਨੰ. 5/LDR5/2023/24 ਮਿਤੀ 12-04-2023 ਐਲ.ਡੀ.ਆਰ ਕੋਨਵੈਂਟ ਸਕੂਲ ਗੁਰੂਹਰ ਸਹਾਏ ਰੋਡ, ਸ੍ਰੀ ਮੁਕਤਸਰ ਸਾਹਿਬ ਰਾਹੀਂ ਟੈਸਟ ਲਈ ਦਿੱਤਾ ਗਿਆ ਸੀ। ਇਸ ਦਫਤਰ ਦੀ ਸਰਕਾਰੀ ਲੈਬੋਰੇਟਰੀ ਵਿੱਚ ਕੈਮੀਕਲ ਟੈਸਟ ਰਾਹੀਂ ਪਾਣੀ ਚੈੱਕ ਕੀਤਾ ਗਿਆ ਅਤੇ ਰਿਪੋਰਟ ਮੁਤਾਬਿਕ ਪਾਣੀ ਦੀ ਕੁਆਲਟੀ ਠੀਕ ਪਾਈ ਗਈ।

ਨੋਟ:- ਇਸ ਸਰਟੀਫਿਕੇਟ ਦੀ ਮਿਆਦ ਇੱਕ ਸਾਲ 2023-24 ਹੈ।

ਉਪਮੰਡਲ ਇੰਜੀਨੀਅਰ,
ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪਮੰਡਲ ਨੰ. 2
ਸ੍ਰੀ ਮੁਕਤਸਰ ਸਾਹਿਬ।

DISTRICT WATER TESTING LABORATORY, SH. MUKTSAR SAHIB

Water Supply and Sanitation Department, Division no 1, kotkapoor road near vishal mega Mart ,Distt Muktsar ,Pin
code 152026
dwtlmks@gmail.com

To,

L.D.R.CONVENT SCHOOL
LAMBI DHAB MUKTSAR


No.: DWTL/MKS/2324/00022 Dated : 19/04/2023

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 4 Dated: 12/04/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 12/04/2023. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Sh. Muktsar Sahib

D/A : Test Report



Authorized Signatory
For, District Water Testing Laboratory, Sh.
Muktsar Sahib

DISTRICT WATER TESTING LABORATORY, SH. MUKTSAR SAHIB

Water Supply and Sanitation Department, Division no 1, kotkapoora road near vishal mega Mart ,Distt Muktsar ,Pin
code 152026
dwtlmks@gmail.com



TEST REPORT

Name & Address of Customer : L.D.R. CONVENT SCHOOL LAMBI DHAB MUKTSAR			Customer Reference No.		No : 4 Dated : 12/04/2023	
			Sample Submitted by		L.D.R. CONVENT SCHOOL	
			Date of Sample Receipt		12/04/2023	
			Analysis Starting Date		12/04/2023	
			Analysis completion Date		13/04/2023	
Discipline : Chemical Testing			Group: Water			
ULR No.:		TC997723000000098F		Sample Type :		Treated Water
Test Report No.:		DWTL/MKS/2324/00022		Date of Issue :		19/04/2023
Registration no.:		DWTL/MKS/REG2324/00036		Condition of Sample :		Sealed
Collection Point:		Treatment Plant (RO/CWPP/ARP/HH Purifier)		Quantity/Type of Bottle:		1000 ml / Amber Colored Glass Bottle
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		L.D.R. CONVENT SCHOOL LAMBI DHAB MUKTSAR / NA
Village :		Lambi Dhab		Habitation :		Lambi Dhab
Block:		Muktsar		District :		Muktsar
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.65	6.5-8.5	No Relaxation	—	IS 3025 (Part 11-1993) Electrometric Method
2	Colour	1.0	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	agreeable	Agreeable	Agreeable	—	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	agreeable	Agreeable	Agreeable	—	IS 3025 (Part 8 – 1984) (RA 2017)
5	TDS	80	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6	Turbidity	0.6	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7	Alkalinity	48	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8	Hardness	52	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
9	Calcium	12	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	5	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method



11	Chloride	20	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method
----	----------	----	-----	------	------	---

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used be as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory, Sh.
Muktsar Sahib

----- End of the Test Report -----

DISTRICT WATER TESTING LABORATORY, SH. MUKTSAR SAHIB

Water Supply and Sanitation Department, Division no 1, kotkapoora road near vishal mega Mart ,Distt Muktsar ,Pin code 152026.
dwtlmks@gmail.com

INVOICE

Bill No. : INV/2324/00036

Date. : 12/04/2023

To,

L.D.R.CONVENT SCHOOL
LAMBI DHAB MUKTSAR

Ref. : Letter No. 4 Dt. 12/04/2023

Sample Receiving No. DWTL/MKS/R2324/00036 Dt.
12/04/2023

Sr. No.	Name of Scheme / Source / Location	Nature of Sample	Category Name	Test Parameter	No. of Sample	Rate Per Parameter/ Set of Parameters	Net Amount
1	Lambi Dhab, L.D.R. CONVENT SCHOOL LAMBI DHAB MUKTSAR	Treated Water	Private Schools	Basic Chemical : pH, Colour, Odour, Taste, TDS, Turbidity, Alkalinity, Hardness, Calcium, Magnesium, Chloride	1	130.00	130.00
Total							130.00
One Hundred Thirty Only.							
Payment Mode : Cash			Payment Status : PAID			STR No. : NA	

Note:- * Discount applicable as per Government Notification Number : No 9284 & Date : 09/11/2021

Authorised Signatory

Office of Sub Divisional Engineer, W/S & Sanitation Sub Division No. 2, Sri
Muktsar Sahib


No. 321

Dated: 03-05-23

"Sanitary Conditions Certificate"

It is certified that L.D.R Convent School, vill. Lambi Dhab District Sri
Muktsar Sahib has well maintained drainage and cleanliness. Drinking water facility is
good. The Sanitary conditions of above said school are good.

Note: This Certificate is valid for only one year 2023-24.


Sub Divisional Engineer,
W/S & Sanitation Sub Div 2,
Sri Muktsar Sahib